
E5 -03: Beam and Block - Parallel

Psi Value: 0.036 W/mK

f Value: 0.88



Thermal Compliance Notes

1. 40mm PIR rigid insulation upstand (0.022 W/mK).
2. 150mm PIR rigid insulation (0.022 W/mK).

Construction Notes

1. Non-masonry cladding system to be specified and detailed by Principal Designer.
2. When using non-masonry cladding systems, A2 fire rated sheathing is a requirement in England and Wales. It is the Principal Designer's responsibility to confirm fire safety requirements for non-masonry cladding systems in all regulatory locations.
3. Subfloor ventilation, subject to building regulations requirements.
4. Holding down straps, subject to timber engineering design.
5. Membrane and VCL shown may help improve air tightness performance.

General Notes

1. The timber frame detailing arrangements shown are considered common industry practice and align with STA technical guidance and advice where required.
2. All non-timber frame construction detailing, design and specifications, are the responsibility of the Principal Designer.
3. Substructure detailing and ground floor construction, is subject to structural engineer's project specific design, under the responsibility of the Principal Designer.