
E20-01: Integral Garage - External Ceiling - I-Joists

Psi Value: 0.045 W/mK

f Value: 0.92



Thermal Compliance Notes

1. 1x150mm, 1x100mm mineral wool insulation (0.044 W/mK) compressed to joist void.
2. Insulation required to meet fire regulations.
3. Cavity barrier.

Construction Notes

1. At floor levels, allowing for building tolerances, an OSB cover plate or solid timber header joist, can be used to maintain cavity dimension, if required.
2. Horizontal cavity barriers at floors and openings, with masonry cladding, should be protected and drained as required.
3. Membrane and VCL shown may help improve air tightness performance.

General Notes

1. The timber frame detailing arrangements shown are considered common industry practice and align with STA technical guidance and advice where required.
2. All non-timber frame construction detailing, design and specifications, are the responsibility of the Principal Designer.
3. All horizontal and vertical cavity barriers and firestops (timber, polythene sleeved or open state) are to be located and fitted in accordance with STA cavity barrier and firestopping technical guidance.
4. Brick wall ties are shown indicatively, and are subject to coursing and structural engineering project specific design, under the responsibility of the Principal Designer.